

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 523

Dated:

It is certified that an inspection team headed by Kolhapur Municipal Corporation

(Name of Officers with designation) from Mr. Nandkumar Y. Kamble PHED

inspected the New Model English School, 2130 E, Tarabai Park, Kolhapur

(Name & Address of the school) on 15/5/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DPHL KR/W-372/05/1 dated 15/05/2025

of District Public Health Lab, Kolhapur (PHED Lab) certified that the

New Model English School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 15/5/2026.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

आरोग्य विरक्षक

कोल्हापूर महानगरपालिका

Mr. Nandkumar Y. Kamble

Sanitary Inspector

Sanitation Ward,
E-4, Kolhapur.

To

New Model English School,
2130, E, Tarabai Park, Kolhapur.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal

NEW MODEL ENGLISH SCHOOL

2130, E, Tarabai Park, Kolhapur
Maharashtra, Pin- 416003

Manager

NEW MODEL ENGLISH SCHOOL

2130, E, Tarabai Park, Kolhapur
Maharashtra, Pin- 416003



सत्यमेव जयते

कनिष्ठ वैज्ञानिक अधिकारी
Junior Scientific Officerजिल्हा सार्वजनिक आरोग्य प्रयोगशाळा, कोल्हापूर
District Public Health Laboratory, Kolhapur330/2 B, Y. P. Powar Nagar Chowk, Bendre Bldg., Kolhapur-416 012.
☎ (0231) 2651582. Email : ccdphikop@gmail.com

Report on Analysis of Water for Drinking purposes

No. DPHL KR/W-377/05/ 1453 /2025

15/5/25

Date: /05/2025

SAMPLE DATA		
Sample Of: Tap water	Source address: NEW MODEL ENGLISH SCHOOL, 2130 E, Tarabai Park, Kolhapur	
Container details : Plastic Bottle	Letter details : Date: 08/05/2025	
Collected on : 08/05/2025	Received at lab on : 08/05/2025	Testing completed on : 13/05/2025
Sender details: NEW MODEL ENGLISH SCHOOL, 2130 E, Tarabai Park, Kolhapur		
Std. Reference- Amendment no.1 June 2015 DRINKING WATER - SPECIFICATION		

TEST DATA						
Sr. No	Parameter	Result	Unit	As per IS 10500:2012		Method
				Acceptable Limit	Permissible Limit	
Organoleptic and Physical Parameter						
1	Physical appearance	Clear	--	--	--	APHA Ed.22 nd (2012)
2	Odour	Agreeable	--	Agreeable	Agreeable	
3	pH	6.5	--	6.5 - 8.5	No Relaxation	
4	Turbidity	0.80	NTU	1.0	5.0	
5	Total Dissolved Solid	24.0	mg/litre	500.0	2000.0	
General parameter concerning substances undesirable in excessive amount						
6	Chloride (as Cl)	3.68	mg/litre	250.0	1000.0	APHA Ed.22 nd (2012)
7	Fluoride (as F)	Not Detected	mg/litre	1.00	1.50	
8	Iron (as Fe)	Not Detected	mg/litre	1.0	No Relaxation	
9	Nitrate (as NO ₃)	Not Detected	mg/litre	45.0	No Relaxation	
10	Total Alkalinity (as CaCO ₃)	5.20	mg/litre	200.0	600.0	
11	Total Hardness (as CaCO ₃)	9.90	mg/litre	200.0	600.0	
END OF TEST RESULT						

REMARKS

- ❖ The sample is not collected by laboratory
- ❖ Analysis results pertain only to 'as received' sample and without prejudice to its source/process.
- ❖ The sample is potable and chemically fit for drinking purpose on the basis of analysed parameter only. However can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly
- ❖ विश्लेषण घटक आधारावर रासायनिक दृष्ट्या सदर नमुना पिण्यास योग्य असून, योग्य प्रक्रिया वा निर्जंतुकीकरण करून अणुजीवीय विश्लेषणांती पिण्यास योग्य असल्याची खात्री झाल्यानंतरच पाणी पिण्यासाठी वापरावे.

----- END OF REMARKS -----

Principal

NEW MODEL ENGLISH SCHOOL
2130; E, Tarabai Park, Kolhapur
Maharashtra, Pin- 416003

Manager

NEW MODEL ENGLISH SCHOOL
2130; E, Tarabai Park, Kolhapur
Maharashtra, Pin- 416003Junior Scientific Officer
Dist. Public Health Laboratory
Kolhapur-416 010